


- 1. ALL LEVELS ARE IN METERS ABOVE SEA LEVEL.
- 2. COORDINATES ARE BASED ON UTM.
- 3. LOCATION OF AIR VALVES, WASHOUTS, BENDS AND OTHER FITTINGS AS SHOWN UNLESS OTHERWISE DIRECTED BY THE ENGINEER ON SITE.
- GROUND AND INVERT LEVEL SHOWN ARE AS SHOWN ON DRAWING UNLESS OTHERWISE INDICATED ON SITE BY THE ENGINEER.
- PIPES ARE TO BE LAID TO EVEN GRADIENTS WITH A MINIMUM COVER OF 1.0M. WHERE COVER IS LESS THAN THIS, PIPE TO BE SURROUNDED WITH CONCRETE
- ALL BENDS ARE HORIZONTAL UNLESS OTHERWISE STATED.
- IN WATER LOGGED AREAS, PIPES TO BE BEDDED WITH SINGLE SIZED OR GRADED AGGREGATES AS PER CLAUSE 430.1 AND 216 OF TECHNICAL SPECIFICATIONS AND/OR ANCHOR BLOCKS AS MAY BE DIRECTED ON SITE BY THE ENGINEER.

LEGEND:

- PROPOSED PIPELINE
- EXISTING GROUND PROFILE
- - PIPE INVERT PROFILE





- DOUBLE AIR VALVE

- WASHOUT

- WASHOUT TYPE 1

- WASHOUT TYPE 2 WO2

- NOMINAL DIAMETER

- NOMINAL PRESSURE

- VERTICAL BEND

- HORIZONTAL BEND

- EXISTING STRUCTURE

- EARTH ROAD

- GRAVEL ROAD

- CUT

FOR CONSTRUCTION

REV	V REVISIONS		SIGN	DATE	APPROVED
		BY			
		CHECKED			
		BY			
		CHECKED			
		BY			
		CHECKED			
co		BY			
~ _		CHECKED			1

CLIENT



TANA WATER WORKS DEVELOPMENT AGENCY P. O. BOX 1292-10100 NYERI

NGARIAMA NJUKINI WATER PROJECT

Civil/Structural Engineers



TANA WATER WORKS DEVELOPMENT AGENCY P. O. BOX 1292-10100 NYERI

NGARIAMA NJUKIINI WATER PROJECT

MBIRI-GICHONJO PIPELINE PLAN AND PROFILE (SHEET 1 OF 6)

Designed by DWN	Drawn by EWN		
Checked by JMM	Approved by		
Scale AS SHOWN (A1)	Date MAY, 2022		
Job No. 1	ACAD File:		

COSTATUS DRAWING NOTWWDA/NNWP/MG-001 REV