


- 1. ALL LEVELS ARE IN METERS ABOVE SEA LEVEL.
- 2. COORDINATES ARE BASED ON UTM.
- 3. LOCATION OF AIR VALVES, WASHOUTS, BENDS AND OTHER FITTINGS AS SHOWN UNLESS OTHERWISE DIRECTED BY THE ENGINEER ON SITE.
- GROUND AND INVERT LEVEL SHOWN ARE AS SHOWN ON DRAWING UNLESS OTHERWISE INDICATED ON SITE BY THE ENGINEER.
- PIPES ARE TO BE LAID TO EVEN GRADIENTS WITH A MINIMUM COVER OF 1.0M. WHERE COVER IS LESS THAN THIS, PIPE TO BE SURROUNDED WITH CONCRETE
- ALL BENDS ARE HORIZONTAL UNLESS OTHERWISE STATED.
- IN WATER LOGGED AREAS, PIPES TO BE BEDDED WITH SINGLE SIZED OR GRADED AGGREGATES AS PER CLAUSE 430.1 AND 216 OF TECHNICAL SPECIFICATIONS AND/OR ANCHOR BLOCKS AS MAY BE DIRECTED ON SITE BY THE ENGINEER.

## LEGEND:

- PROPOSED PIPELINE
- EXISTING GROUND PROFILE
- PIPE INVERT PROFILE





- DOUBLE AIR VALVE

## - WASHOUT

- WASHOUT TYPE 1

- WASHOUT TYPE 2

- NOMINAL DIAMETER - NOMINAL PRESSURE

VERTICAL BEND

- HORIZONTAL BEND

- EXISTING STRUCTURE

- EARTH ROAD

- GRAVEL ROAD

- CUT

## FOR CONSTRUCTION

	,				
REV	V REVISIONS		SIGN	DATE	APPROVED
		BY			
		CHECKED			
		BY			
		CHECKED			
		BY			
		CHECKED			
со		BY			
100		CHECKED			



TANA WATER WORKS DEVELOPMENT AGENCY P. O. BOX 1292-10100

NGARIAMA NJUKINI WATER PROJECT

## Civil/Structural Engineers

TANA WATER WORKS DEVELOPMENT AGENCY P. O. BOX 1292-10100 NYERI

MBIRI-GICHONJO PIPELINE PLAN AND PROFILE (SHEET 2 OF 6)

	Designed	l by DWN	Drawn by EWN		
	Checked	by JMM	Approved by		
Scale AS SHOWN (A1)			Date MAY, 2022		
	Job No.	1	ACAD File:		