

NOTES:

- 1. DIMENSIONS IN mm UNLESS OTHERWISE SPECIFIED
- 2. ALL EXPOSED CONCRETE EDGES TO HAVE A 25mm x 25mm CHAMFER
- 3. CONCRETE WORKS: ALL REINFORCED CONCRETE TO BE CLASS 25/20 EXCEPT WHERE OTHERWISE SPECIFIED
- 4. ABBREVIATIONS
 - R.C REINFORCED CONCRETE D.P.C - DAMP PROOF COURSE E.G.L - EXISTING GROUND LEVEL F.G.L - FINISHED GROUND LEVEL F.F.L - FINISHED FLOOR LEVEL P.C.C - PRECAST CONCRETE G.C.I - GALVANIZED CORRUGATED IRON
- 5. EDGES OF TREADS AND RISERS IN CONCRETE STAIRCASE TO BE PROTECTED WITH 40 x 40 x 3mm M.S. ANGLE FIXED WITH FISH TAIL LUGS EMBEDDED IN CONCRETE
- 6. FOR WINDOW SCHEDULE SEE DRG. NO. M407/SD/25
- FOR DOOR SCHEDULE SEE DRG NO. M407/SD/26-27
- 8. ALL VENT BLOCKS UNDER WINDOWS TO BE PROVIDED WITH PVC GAUZE IN TIMBER FRAMING
- 9. ALL INTERNAL SURFACES OF MIXING TANKS TO BE LINED WITH THREE COATS OF APPROVED EPOXY LINING
- 10. DETAIL OF DOSER PLATFORM IS SHOWN FOR OPADOS TYPE DOSERS. IF DIFFERENT TYPE OF DOSER IS PROPOSED, CONTRACTOR TO SUBMIT TO ENGINEER DETAILS OF DOSER AND SUITABLE PLATFORM(S) BEFORE COMMENCING CONSTRUCTION OF MIXING TANK WALLS.

CLIENT:	TANA WA	ECUTIVE OF	
	P.O BOX 129	MENT AGEN	C Y
Add Allowin Redig	NYERI, KENY	1	
ENGINEER:	SERVICE	-	
		TER WORKS	
Juliane appe	P.O BOX 129		C1
	NYERI, KENY	Ά	
TETU AG	UTHI WAT	ER SUPPLY	PROJECT
DRAWING TITLE: TETU WATER TREATMENT WORKS			
ELEVATIONS			
Designed by:	K.N.G.	Drawn by:	R.M.N.
Checked by:	J.M.M	Approved by:	D.N.M
Scale: NTS		Date:	JAN 2024
DRG No.	TAWF	P/CSMB/06	