



**TREATED WATER TANK
BASE SLAB PLAN**

- NOTES:**
- ALL DIMENSIONS IN MILLIMETERS UNLESS OTHERWISE INDICATED
 - ALL EXPOSED CONCRETE EDGES TO HAVE A 25mm x 25mm CHAMFER
 - CONCRETE WORKS: ALL REINFORCED CONCRETE TO BE CLASS 25 /20 EXCEPT WHERE OTHERWISE SPECIFIED
 - ABBREVIATIONS:
 - R.C - REINFORCED CONCRETE
 - F.G.L - FINISHED GROUND LEVEL
 - E.G.L - EXISTING GROUND LEVEL
 - DN - NOMINAL DIAETER
 - uPVC - UNPLASTICISED POLYVINYL CHLORIDE
 - G.I - GALVANIZED IRON

CLIENT: **CHIEF EXECUTIVE OFFICER
TANA WATER WORKS
DEVELOPMENT AGENCY**
P.O BOX 1292 - 10100,
NYERI, KENYA

ENGINEER: **CHIEF MANAGER TECHNICAL
SERVICES
TANA WATER WORKS
DEVELOPMENT AGENCY**
P.O BOX 1292 - 10100,
NYERI, KENYA

PROJECT TITLE:

TETU WATER SUPPLY PROJECT

DRAWING TITLE:
TETU WATER TREATMENT WORKS

**TREATED WATER TANK (500m³)
BASE SLAB PLAN**

Designed by: K.N.G	Drawn by: A.M.M
Checked by: J.M.M	Approved by: D.N.M
Scale: 1:100	Date: JAN 2024

DRG No. **TAWP/TWT/02**