


- This drawing shall be read in conjunction with architectural drawings and in the event of any discrepancy, the Engineer and the Architect shall be notified before proceeding with the works.
- All dimensions are in millimeters unless specified otherwise.
- All dimensions shall be verified by the contractor and drawings shall not be scaled off. Only figured dimensions shall be used.
- The depth of foundation shall be to hard stratum and approved by the structural engineer.
- Concrete shall have 20mm maximum size of aggregates and shall be adequately vibrated and cured. Concrete strength shall be:
  - a) Blinding = 15/20 (1:4:8)
  - b) Foundation, Column Bases & Columns = 25/20 (1:1.5:3)
- Concrete cover to reinforcement steel to be:
  - a) Foundations = 50MM
  - b) Columns = 30MM
  - c) Beams = 25MM
- All steel to design B.S.4461.
- Load Parameters:
  - a) The Load = 1.5KN/M<sup>2</sup>
  - b) Wind Load =

REV	DATE	DESCRIPTION	SIGN
CLIENT			TANA WATER WORKS DEVELOPMENT AGENCY
JOB			12M HIGH ELEVATED WATER TANK TOWER FOR 24M <sup>3</sup> STEEL TANK
STRUCTURAL & GENERAL ARRANGEMENT OF TOWER STEEL WORKS			DRG. NO. 01
DRAWN BY		DRAWN BY	
TANA WATER WORKS DEVELOPMENT AGENCY P.O BOX 1292-10100 NYERI KENYA		AS SHOWN	
CHECKED BY		DATE	
SCALE		FEBRUARY 2021	
		REV	



minimum depth to be 1500mm to be determined on site  
50mm thick blinding