



AFRICAN DEVELOPMENT BANK GROUP



TANA WATER WORKS DEVELOPMENT AGENCY (TWWDA) AND NORTHERN WATER WORK DEVELOPMENT AGENCY

ADDENDUM NO.1 UNDER SPECIFIC PROCUREMENT NOTICES (SPNS)

- (i) Tana Water Works Development Agency (TWWDA) wishes to draw the attention of all Interested Bidders in the Invitation for Bids (IFB) for the supply and delivery of the here-under listed goods, as had been advertised in the Daily Nation paper, and similarly uploaded on the PPIP and TWWDA Website on Thursday 15th May 2025 to the following adjustments/Changes/Clarifications to the IFBs as indicated in the table below:
- (ii) This addendum relates to the adjustments made on the respective Bids Data Sheet (CDS) and deadline for the submission of the bids. The changes/clarifications are now uploaded on the Agency's website (www.tanawwda.go.ke).

IFB	Indicated Details in the Advertised Tender/Inquiry made by potential bidders	Clarification/Change/s Made
1. Supply and Delivery of Water Meters for Kirinyaga County Water and Sanitation Company and Nithi Water and Sanitation Company – LOT 1 (TWWDA/ADB/002/2024-2025).	<p>-Section VII – Schedule of Requirements</p> <p>3. Technical Specifications</p> <p>3.0 Specifications for Water Meters</p> <p>Page 97 of the documents: Section 3 on Specifications for Water Meters, – the type mentioned is multi-Jet velocity type while the second paragraph states that volumetric/positive displacement meter is required.</p> <p>– Can a bidder quote for Single Jet Meters as these are by far the best type of meters for Kenyan conditions as they are designed to deal with loaded water?</p>	<p>Paragraph 2 of the Specifications is changed as follows: The meters must comply with EN ISO 4064: 2014, OIML R 49 :2013 and MID 2014/32/EU. The meters shall be the Multi-Jet Type (positive displacement meter), R=160, accuracy class 1, for installation in any position (except overhead)”</p> <p>Refer to Clarification No. 1, meters shall be the Multi-Jet Type</p>
2. Supply and Delivery of Water Meters for Mandera Water and Sewerage Company and Marsabit Water and Sewerage Company – LOT 2 (TWWDA/ADB/003/2024-2025).	<p>-Section VII – Schedule of Requirements</p> <p>3. Technical Specifications</p> <p>3.0 Specifications for Water Meters</p> <p>Page 97 of the documents: Section 3 on Specifications for Water Meters, – the type mentioned is multi-Jet velocity type while the second paragraph states that volumetric/positive displacement meter is required.</p> <p>– Can a bidder quote for Single Jet Meters as these are by far the best type of meters for Kenyan conditions as they are designed to deal with loaded water?</p> <p>– Shall Accuracy Class 2 meters be accepted</p>	<p>Paragraph 2 of the Specifications is changed as follows: The meters must comply with EN ISO 4064: 2014, OIML R 49 :2013 and MID 2014/32/EU. The meters shall be the Multi-Jet Type (positive displacement meter), R=160, accuracy class 1, for installation in any position (except overhead)”</p> <p>Refer to Clarification No. 1, meters shall be the Multi-Jet Type</p> <p>Bidder shall only quote for Accuracy Class 1 Meters</p>
3. Supply and Delivery of Leak Detection Equipment (TWWDA/ADB/004/2024-2025).	<p>-Section VII – Schedule of Requirements</p> <p>3. Technical Specifications</p> <p>3.0 Specifications for Leak Detection Equipment</p> <p>Can we offer.</p> <p>1 x Acoustic Ground Microphone Kit (to pin point the exact location of the leaks-usually within 30cm), including 1 x Main Unit with Digital Display, 1 x Listening Tip for Valves, Hydrants and Soft Ground, 1 x Tripod Adaptor for Hard Surfaces, 1 x Wind/Ambient Noise Insulator, 1 x Wireless Headphones, Carry Bag, 1 x Mains Charger and 1 x 12V Car Charger and 1 x Measuring Wheel as part of our offer or as optional extras which can be priced, but not included in final totals?</p> <p>While the tender Technical Specifications are drawn from a particular brand, can we offer a more advanced CORRELATOR Model with better specifications?</p>	<p>Alternative bids shall NOT be allowed (Refer to ITB 13.1)</p> <p>Alternative bids shall NOT be allowed (Refer to ITB 13.1)</p>

- (iii) Further to the addendum, all bidders are hereby informed that the deadline for submission of the bids has now been extended from the earlier set date of Wednesday, 4th June 2025 at 10.00 a.m. to **Wednesday 18th June 2025 at 10.00 a.m.** Consequently, all details in the named Bid documents relating to the submission deadline shall change accordingly.
- (iv) This addendum shall form part of the named Tender Document and be construed as such pursuant to the section on 'Amendments of Bid Documents' as explained in the bid.

For further clarification, kindly use the email address indicated: ceo@tanawwda.go.ke

Chief Executive Officer,

Tana Water Works Development

Agency, P.O Box 1292-10100, NYERI

Addendum Dated: 03/06/2025